

ZERTIFIKAT

CERTIFICATE

Nr./No. 968/EL 224.00/03

Prüfgegenstand Product tested	Safety Relay Unit	Hersteller Manufacturer	BTInternational Fabricant de composants d'automatisme et de sécurité Z.I. des Richardets 34, Allée de Closeau 93160 Noisy le Grand France
Typbezeichnung Type designation	AWAX26XXL	Verwendungszweck Intended application	Safeguard at machinery and other hazardous areas, control of emergency stop push buttons and interlock switches
Prüfgrundlagen Codes and standards forming the basis of testing	EN 1088:1995 EN 954-1:1996 EN 418:1992 EN 60204-1:1997 EN 50178:1997 DIN EN 60947-1:2002 DIN EN 60947-5-1:2000		
Prüfungsergebnis Test results	The requirements of safety category 3 according to EN 954-1 are fulfilled. The requirements of safety category 4 according to EN 954-1 are fulfilled if the output is cycled by the application at regular intervals.		
Besondere Bedingungen Specific requirements	The device has to be installed in an enclosure / cabinet which meets at least IP54. Wiring / cabling insulation between safety relay and all external components must withstand a nominal voltage of 250VAC.		

Der Prüfbericht-Nr.: 968/EL 224.00/03 vom 27.06.2003 ist Bestandteil dieses Zertifikates.

Dieses Zertifikat ist nur gültig für Erzeugnisse, die mit dem Prüfgegenstand übereinstimmen. Es wird ungültig bei jeglicher Änderung der Prüfgrundlagen für den angegebenen Verwendungszweck.

The test report-no.: 968/EL 224.00/03 dated 2003-06-27 is an integral part of this certificate.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

TÜV Rheinland Industrie Service GmbH
Geschäftsfeld ASI
Automation, Software und Informationstechnologie
Am Grauen Stein, 51105 Köln
Postfach 91 09 51, 51101 Köln



2003-06-27
Datum/Date

Firmenstempel/Company Seal

Unterschrift/Signature